



To

The Principal,
Cecil Convent School,
Staff Road, Ambala Cantt.

No. 1113 Dated: 12/3/2024

Subject: Renewal of the Building Safety Certificate
(Regarding Building Safety Certificate for the year 2023 – 24).

Reference: Your office Letter No. CCS / 10 dated 29.01.2024.

The School Building i.e. Cecil Covent School, Opp. GPO, Staff Road, Ambala Cantt has been visually inspected by the SDE P-6 alongwith JE concerned and who have reported that building is visually safe for running school. The proof checked structural drawings from Govt. agency are by the school. Hence, the School Building Safety Certificate is hereby given upto the period 2023 – 24 with the following conditions: -

1. Building of this School should be repaired every year.
2. Water should not be allowed to stagnate around and on the roof of the Building.
3. If Building is found cracked from anywhere, the same should be got vacated immediately and same should be got repaired immediately.
4. Institution will be responsible for safety of building from every angle and Fire-Fighting equipment should be in functional condition.
5. If the building of the school is to be extended, the same should be first approved from Structural Engineer.
6. Adequate Fire safety may be adopted in the school campus.
7. Institute shall also ensure safety precautions from false ceiling and vitrified tiles used in dado.
8. NOC may be considered as cancelled by this office if the School violates any of the above points.

DA/NIL

Executive Engineer,
Provincial Division No.1,
PWD B&R Br; Ambala Cantt.

Endst. No.

Dated:-

Copy of the above is forwarded to the Sub Divisional Engineer, Provincial Sub Division No. 6, PWD B&R Br; Ambala Cantt for information w.r.t. this office No. 132 dated 11.03.2024.

DA/ NIL

Executive Engineer,
Provincial Division No.1,
PWD B&R Br; Ambala Cantt.